

□ Model 5867

Lead free plastic pressure regulator currently used on all Haws "Hands-Off" sensor operated drinking fountains. This valve exceeds the standards of the Safe Drinking Water Act and Lead Contamination Control Act. All components in the waterway contain less than 0.1% lead.

Service Instructions for Model 5867:

If stream height of water is unsatisfactory, flush regulator thoroughly to remove all debris. Then adjust stream by first loosening locknut and then turn adjusting screw clockwise to raise, counter clockwise to lower. Tighten lock nut when complete. If regulator continues to malfunction, replace with complete regulator. Individual replacement parts are not available.

